

# Fire and Generator Room Code

(Disponible seulement en anglais)

## Extracts from the National Fire Code of Canada - 2005 (Disponible seulement en anglais)

### 2.7.3 Safety to Life

#### 2.7.3.1. Installation and Maintenance

- 1) Exit lighting, exit signs and emergency lighting shall be provided in buildings in conformance with the NBC. (See Appendix A.)
- 2) Exit lighting and exit signs shall be illuminated during times when the building is occupied.
- 3) Emergency lighting shall be maintained in operating condition, in conformance with Section 6.5.

### Section 6.5 Emergency Power Systems and Unit Equipment for Emergency Lighting

#### 6.5.1.1. Inspection, Testing and Maintenance

- 1) Except as provided in Articles 6.5.1.2. to 6.5.1.5., emergency power systems shall be inspected, tested and maintained in conformance with CAN/CSA-C282, "Emergency Electrical Power Supply for Buildings."
- 2) An emergency electrical power supply system for emergency equipment for health care facilities shall be inspected, tested and maintained in conformance with CAN/CSA-Z32, "Electrical Safety and Essential Electrical Systems in Health Care Facilities." (See Appendix A.)

#### 6.5.1.6. Inspection of Unit Equipment

- 1) Self-contained emergency lighting unit equipment shall be inspected at intervals not greater than one month to ensure that
  - a) pilot lights are functioning and not obviously damaged or obstructed,
  - b) the terminal connections are clean, free of corrosion and lubricated when necessary,
  - c) the terminal clamps are clean and tight as per manufacturer's specifications, and
  - d) the battery surface is kept clean and dry.
- 2) Self-contained emergency lighting unit equipment shall be tested
  - a) at intervals not greater than one month to ensure that the emergency lights will function upon failure of the primary power supply, and
  - b) at intervals not greater than 12 months to ensure that the unit will provide emergency lighting for a duration equal to the design criterion under simulated power failure conditions.
- 3) After completion of the test required in Clause (2)(b), the charging conditions for voltage and current and the recovery period shall be tested to ensure that the charging system is functioning in accordance with the manufacturer's specifications.

#### 6.5.1.7. Inspection of Emergency Lights

- 1) Except as provided in Article 6.5.1.6., emergency lights shall be inspected at intervals not greater than 12 months to ensure that they are functional.

## Generator Room Code – Extracts from the Canadian Standard Association - CSA C282-05 (Disponible seulement en anglais)

### Section 6.11 Emergency Lighting

#### 6.11.1 General

- 6.7.1.1.** The emergency electrical power supply room and the automatic transfer switch room, where separate, shall be equipped with unit equipment for emergency lighting that complies with CSA C22.2 No. 141. Sufficient lamps shall be provided to ensure that a minimum lighting level of 50 lx for 2 h is available at all equipment locations requiring adjustment or service.  
Note: This illumination level is significantly greater than that specified in the NBC, which requires 10 lx for egress route emergency lighting.

- 6.11.2** Emergency lighting units shall be tested in accordance with Table 2 and CSA C22.2 No. 141.

- 6.11.3** The emergency lighting unit shall include
- (a) automatic self-diagnostic circuitry; and
  - (b) a transient voltage surge suppressor on the supply side of power to the unit.